

**Public Health Engineering Department District Water- Testing  
Laboratory Gwalior**

**Test Report**

Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:- Principal Pragati Vidya Peeth C.P. Colony Main Road Morar Gwalior (M.P.)			
Sample No.	Place of Collection and Details of Sample		Date of collection
1	Drinking Water		10.01.2025
2	-		-
3	-		-
4	-		-
Particular of Sample :			
Date of Receipt: 10.01.2025		Time of Receipt: 01:30 PM	
Lab Reference No:		Date of Analysis: 13.01.2025	
Nature of Study – Chemical and Bacteriological Analysis			

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
<b>PHYSICAL TESTE</b>								
1	Turbidity	NTU	1.0	5.0	1.2	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
<b>CHEMICAL TESTE</b>								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	88	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	62	-	-	-
8	Nitrate as No3	Mg/L	45	45	04	-	-	-
9	Total hardness	Mg/L	200	600	110	-	-	-
10	Calcium as Ca	Mg/L	75	200	20	-	-	-
11	Magnesium as mg	Mg/L	30	100	14	-	-	-
12	Iron	Mg/L	0.3	1.0	0.10	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	253	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.11	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	06	-	-	-
<b>BECT. FEACAL TESTE</b>								
17	MPN of coliform	per 100 ml	Nil		-	-	-	-
18	Faecal Coliform	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Signature of Analyst  
District Lab Gwalior  
P.H.E. Division Gwalior

Lab In charge  
P.H.E. Division Gwalior (M.P.)  
P.H.E. Division, Gwalior (M.P.)

No. 305 /PHED/ Date :- 14/01/2025